

US EPA RECORDS CENTER REGION 5



487749

August 15, 1977

Mr. Keith Patterson, Mgr.
Industrial Engineering
TRW Portland Works
902 Lyons Rd.
Portland, MI 48875

Re: Pollution Incident Prevention Plan
TRW Portland Works 12160
PCB Addendum PCB

Dear Mr. Patterson:

We hereby acknowledge receipt of the PCB Addendum to your pollution incident prevention plan submitted in accordance with the Rule R 323.1162 of Part 5 of the Water Resources Commission Administrative Rules.

It has been assigned to John Cosens, our District Engineer, for review and recommended action. In accordance with the rules, if the plan is determined to be inadequate or incomplete, it will be returned to you for modifications. Upon receipt of a satisfactory plan, formal approval will be granted.

Should you wish to make further inquiry during the review of the plan, please contact Mr. Cosens at 517-373-7886, Lansing, Michigan.

Very truly yours,

WATER RESOURCES COMMISSION

Robert J. Courchaine
Executive Secretary

RJC/RWP:clp

cc: J. Bohunsky

J. Cosens ✓

R. Parker

P. Blakeslee

RECEIVED

AUG 17 1977

Water Qual. Control

TRW

May 24, 1977

RECEIVED

Water Qual. Control

Robert Courchaine
Chief Engineer, Water Resources Commission
P.O. Box 30028
Lansing, Michigan 48909

Dear Sir:

In response to Mr. Richard Powers' letter re: our PIPP in regard to PCB, we are submitting the following supplement to our plan #12160.

We have just one piece of equipment in our plant that contains PCB. This is an ITE 2000 KVA transformer containing immersed Askarel. The transformers capacity is 465 gallons. As near as we can determine the Askarel contains approx. 60% PCB or 279 gallons. (For reference we contacted ITE Imperial in Detroit and Monsanto Enviro-Chem. Systems.)

The transformer is located in a cement block room that has 4" curb in all openings and doorways. This will allow for containment of a spill capacity of 934 gallons and is sufficient to handle any spill that might occur in this area. The area is locked to keep out all unauthorized personnel and has two signs posted by the area indicating that the transformer contains PCB.

I hope our prevention plan will meet your approval as a PIPP program. If there are any questions concerning our program, please contact me.

12160
PCB ADDENDUM
ORIG PIPP R'CD 2-27-77
DIST APP 4-16-77
WRC APP 5-1-77
RWP

Sincerely,

Keith Patterson
Keith Patterson, Mgr.
Industrial Engineering

cc; John Cosens
Stevens T. Mason Bldg.
Lansing, Michigan

RECEIVED

TRW

May 24, 1977 MAY 28 1977

Water Qual. Control

Robert Courchaine
Chief Engineer, Water Resources Commission
P.O. Box 30028
Lansing, Michigan 48909

Dear Sir:

In response to Mr. Richard Powers' letter re: our PIPP in regard to PCB, we are submitting the following supplement to our plan #12160.

We have just one piece of equipment in our plant that contains PCB. This is an ITE 2000 KVA transformer containing immersed Askarel. The transformers capacity is 465 gallons. As near as we can determine the Askarel contains approx. 60% PCB or 279 gallons. (For reference we contacted ITE Imperial in Detroit and Monsanto Enviro-Chem. Systems.)

The transformer is located in a cement block room that has 4" curb in all openings and doorways. This will allow for containment of a spill capacity of 934 gallons and is sufficient to handle any spill that might occur in this area. The area is locked to keep out all unauthorized personnel and has two signs posted by the area indicating that the transformer contains PCB.

I hope our prevention plan will meet your approval as a PIPP program. If there are any questions concerning our program, please contact me.

Sincerely,

Keith Patterson
Keith Patterson, Mgr.
Industrial Engineering

RECEIVED

MAY 26 1977

cc; TOXIC MATERIALS
John Cosen
CONTROL
Stevens T. Mason Bldg.
Lansing, Michigan